

12V70AH

.....





Features:

- ▲ Maintenance-free operation
- ▲ Stable quality and high reliability
- ▲ Compact design
- \blacktriangle 10 years design time (at 25°C)

Applications:

- **♦** UPS
- **♠** Emergency lighting
- ♦ Solar panel system
- ♠ Alarm and security system
- **♠** Telecommunication system

- ♣ Fire alarm and security systems
- ♠ DC power supply Auto control system
- ♠ Backup power for testing and measuring instruments
- ♠ Electronic apparatus and equipment Communication power supply
- ♠ etc

Specifications:


Type	Specification						
Nominal Voltage	12v(6cells)						
140mmar voltage	70ah (10hrs, 1.80v/cell, 25°C/77°F)						
Nominal Capacity	60ah (5hrs, 1.75v/cell, 25°C/77°F)						
Norminal Capacity							
	42ah (1hrs, 1.60v/cell, 25°C/77°F)						
	Length: 260±2mm						
Dimension	Width: 168±2mm						
	Container Height: 208±2mm						
	Total Height(with Terminal):212±3mm						
Approx Weight	23.0kg						
Terminal	T3 or F5						
Container material	ABS						
Max.Discharge Current	700A(5s)						
Internal Resistance	Approx 6.5mΩ						
	Discharge:-15-50°C(5-122°F)						
Operation Temp.Range	Charge: 0-40°C (32-104°F)						
	Storage: -15-40°C (5-104°F)						
Nominal Operating Temp.Range	25±3℃(77±5°F)						
Cycle Use	14.4V-14.8V(25°C/77°F) Coefficient:30mv/°C (Initial charging current less than 16.5A)						
Standby Use	13.5V-13.8V(25℃/77°F) Coefficient:20mv/℃ (No limit on Initial Charging Current)						
	103% 40°C(104°F)						
Capacity affected by Temp.	100% 25°C(77°F)						
	86% 0°C(32°F)						

Self Discharge:


KANGLIDA batteries maybe stored for up to 6months at 25° C(77°F) and then a freshing charge is required, for higher temperatures the time interval will be shorter.


		C	onstant C	urrent Dis	charge(A	mperes at	25°C/77 °	F)		
F.V/Time	10min	15min	30min	45min	1h	2h	3h	5h	10h	20h
1.80V/cell	129	105	66	50.4	41.0	24.0	18.0	12.4	7.3	3.74
1.70V/cell	151	123	71	54.0	43.6	25.3	18.9	12.8	7.4	3.85
1.60V/cell	169	136	78	58.3	46.8	26.8	19.7	13.3	7.6	3.96
		Co	nstant Po	wer Discha	arge(Watt	s per cell	at 25°C/77	'°F)		
F.V/Time	10min	15min	30min	45min	1h	2h	3h	5h	10h	20h
1.80V/cell	236	199	123	95.8	79.9	46.2	34.9	24.5	14.4	7.41
1.70V/cell	266	220	132	103.0	82.9	48.5	36.4	25.1	14.6	7.60
1.60V/cell	290	238	144	108.7	88.3	50.5	37.7	25.8	14.8	7.79


Note: the above characteristics data are average values obtained within three charge/discharge cycles, not the minimum values. **Dimensions:**





Characteristics:














Attentions:

- 1.After received product, please checked box damaged or not, if find crack on battery body, contact with us and logistics, it should be caused by boorish handle during delivery;
- 2.Don't pull or shake terminal, otherwise, it may cause terminal loosen;
- 3.Battery is not allowed close to Tepid source or basked under the sun for a long time;
- 4. Charge in the obturate container is not allowed;
- 5.No short circuit. Battery should be stored full of electronic when not in need and the battery should be charged every three months in order to avoid the irreversible sulphation. When battery case bursts or electrolyte leaks, battery should be changed lest the acid corrosion.
- 6.No battery in environment with the acid gas.
- 7. When battery is used as the backup battery, be careful and check it at regular time to avoid the damage battery. Especially the battery beyond one year should be checked in time, and change the less capacity and scrapped battery.(some batteries maybe have voltage but no current; some batteries maybe have current but no voltage; some maybe have both but less capacity:all these conditions cannot meet the work,reach the power-on time. Do not forth small battery,cause the huge losses) 8. Forbidden put battery in the fire, otherwise it will cause an explosion.
- 9. When battery cracks or leaks, please use cotton cloth clean it. When skin contacts to the liquid, wash with fresh water immediately. See doctor if serious.
- 10. No wash on the surface of the battery with the organic solution.
- 11.If the equipment uses batteries in groups, the batteries must be selected with similar voltage before usage, otherwise some batteries in the group will be damaged due to inconsistent voltage and internal resistance.
- 12. In the process of recycling the battery, do not use it under the state of dissatisfied charging. As a result, the battery will be sulphated, and the storage performance and capacity will drop to a long-term dissatisfied state; the battery's capacity and efficiency of use will not be obtained.

Zhengzhou Kanglida electronic power Co., LTD

ShenZhen Kanglida electronic power Co., LTD

http://www.kldbattery.com

http://www.com-battery.com

Inttp://www.kldbatteries.com

http://www.kanglidabatteries.com

http://www.comkanglida.com

Email:demi@cnbattery.cn

Email:paulali@cnbattery.cn Tel:86-371-68786444/86-755-22319878